



ADDENDUM NO. 1

TO REQUEST FOR PROPOSALS (RFP) “Water Meter Change-Out Project”

DATE: May 19, 2025

This Addendum is issued to modify and clarify the Request for Proposals (RFP) as follows:

MODIFICATION TO RFP DOCUMENT

Original Language (to be deleted):

5.0 DUTIES AND RESPONSIBILITIES: Meter Replacement (Page 11, Paragraph 2)

"Contractor shall be responsible for properly programming ALL meters included in scope of work using the Trimble Nomad handheld unit or approved equivalent."

Revised Language (to replace original):

"Contractor shall be responsible for properly programming ALL meters included in scope of work using a Sensus Metering, CommandLink, Model # CL200 unit with Field Logic Tools program version 7.8.3. Configuration file to be provided by the owner."

All other terms and conditions of the RFP remain unchanged. Proposers shall acknowledge receipt of this Addendum by including it with their proposal response.

Authorized by:

Juan Roman

Distribution Superintendent

Hendersonville Utility District

615.824.3717 x3105

jroman@hendutil.net